



Addendum No. 3
RFP #4381 Clarification on Question 7 of Addendum No.2

7. Is the City anticipating condition assessment as part of this master plan? If so, are current CCTV inspection reports available?

Original Response from the City

Yes, condition assessment is requested. All CCTV inspection reports will be available through our POSM system.

Updated Response from the City

City is requesting a condition assessment of 12" and larger pipes only. Intent is to determine if pipe replacement is recommended as a capital improvement project due to structural/condition issues, rather than capacity concerns/issues.

END OF ADDENDUM No. 3